

**806.1.1 Restricted occupancies.** Natural cut trees shall be prohibited in the following occupancies:

1. Group I; and
2. R-2 occupancies providing licensed care to clients in one of the categories listed in the International Building Code, section 310.1 licensed by Washington state.

**806.1.2 Support devices.** The support device that holds the tree in an upright position shall be of a type that is stable and that meets all of the following criteria:

1. The device shall hold the tree securely and be of adequate size to avoid tipping over of the tree.
2. The device shall be capable of containing a minimum supply of water in accordance with Table 806.1.2.
3. The water level, when full, shall cover the tree stem at least 2 inches (51 mm). The water level shall be maintained above the fresh cut and checked at least once daily.

**TABLE 806.1.2  
SUPPORT STAND WATER CAPACITY**

Tree Stem Diameter (inches)	Minimum Support Stand Water Capacity (gallons)	Typical Daily Water Transpiration Amount (gallons)
Up to 4	1	¼ to 1
4 to 6	1½	1¼ to 1½
7 to 8	2	1¾ to 2
9 to 12	3	2¼ to 3
13 and over	4	Over 3

(Insert Facing Page 99)